

CERTIFICATE

of Conformity

Low Voltage Directive (EU) 2014/35

Registration No.: AN 50729594 0001
Report No.: CN25YTG1 001
Holder: FIRBESON AUTOMATION UK LTD
Unit 15C, Cosgrove Way
Luton
Bedfordshire
LU11XL
United Kingdom
Product: Control Unit
(Damper Actuator)

Type designation and serial number are listed on the next page(s)

This certificate of conformity is based on an evaluation of a sample of the above-mentioned product. Technical Report and documentation are at the License Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive (EU) 2014/35, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date: 2026-06-18

Certification Body

Kenny Shi



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.

CERTIFICATE

of Conformity

Low Voltage Directive (EU) 2014/35

Registration No.: AN 50729594 0001

Product: Control Unit
(Damper Actuator)

Identification: Type Designation
F30A-aD230-b F30S-cD230-d F30F-eD230-f F30N-gD230-S
F30A-hD230-iQ
(a, b, c, d, e, f, g, h, i are variables)

Rated Voltage	: AC 85-265V
Rated Power	: 1.5-15W
Ambient Temperature Limits	: 30T55
Number of Automatic Cycles	: 1E4
Type Action	: Type 1.AA
Degree of Protection	: IP54 after installation
Type Movement	: Rotary

Serial No.:
Engineering sample

Remark:
Issued in conjunction with test report
CN25YTG1 001.



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

The CE marking may be used if all relevant and effective EC Directives/Regulations are complied with.